



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LABORATORY**  
 KIZHAKKUMPATTUKARA THRISSUR  
 Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com



TC-10416

**Test Report**

Test Report. No :KWA/QCDL/TSR/0466/2024

ULR No.: TC104152400000409F

Report Date: 27.01.2024

Customer Name & Address			1. Date of receipt : 23.01.2024		
<b>Manappuram Geetha Ravy Public School,          Valapad,Mob:9349207835</b>			2. Sampling done by : The Customer		
			3. UID No.of Sample: KWA/QCDL/TSR/S-000466/2024		
			4. Source of sample : Bore Well-Filter Water		
			5. Sample condition : Good		
			6. Name of sample : Drinking water		
			7. Purpose of test : Commercial		
			8. Sample quantity : 2 litre		
			9. Test performing dates From :24.01.2024 To : 24.01.2024		
			Sl. No.	Characteristics	Unit
1	Turbidity	(NTU)	IS 3025 (part 10) - 2023 Nephelometric method	1	0.45
2	pH at 25°C		IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	6.9
3	Total Hardness (as Ca CO <sub>3</sub> )	(mg/litre)	IS 3025 (part 21)-2009 (Reaffirmed. 2019)EDTA titration method	200	2.0
4	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 1988 (Reaffirmed. 2019) Argentometric titration	250	3.9
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2003 (Reaffirmed. 2019) 1,10 Phenanthroline method	1.0	0.39
6	Nitrate (as NO <sub>3</sub> )	(mg/litre)	APHA 4500 - NO <sub>3</sub> B.Ultraviolet screening method	45	0.57

Remarks:-All tested parameters are within the acceptable limit.

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By Ragesh M.K

\* End of Report \*

Quality Manager,  
 Quality Control District Laboratory  
 Kerala Water Authority

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023 680 005
Amend.No: 03	Amend Date: 08.08.2023	Page 1 of 1



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LABORATORY**  
KIZHAKKUMPATTUKARA THRISSUR  
Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com

**Test Report**

Test Report. No : KWA/QCDL/TSR/0466/2024

Report Date : 27.01.2024

<b>Customer Name &amp; Address</b>  <b>Manappuram Geetha Ravy Public School, Valapad, Mob:9349207835</b>			1. Date of receipt : 23.01.2024		
			2. Sampling done by : The Customer		
			3. UID No.of Sample: KWA/QCDL/TSR/S-000466/2024		
			4. Source of sample : Bore Well-Filter Water		
			5. Sample condition : Good		
			6. Name of sample : Drinking water		
			7. Purpose of test : Commercial		
			8. Sample quantity : 2 litre		
			9. Test performing dates From :24.01.2024 To : 24.01.2024		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity	(micro mhos/cm)	IS 3025 (part 14) - 2013 (Reaffirmed. 2019) Electrometric method	-	87.0

Remarks:-

*NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed by: 



Authorized By  Ragesh M.K

Quality Manager,  
Quality Control District Laboratory

Kerala Water Authority

Thrissur - 680 005

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1 of 1



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LABORATORY**

KIZHAKKUMPATTUKARA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

**Test Report**

Test Report. No :KWA/QCDL/TSR/0466/2024

Report Date : 27.01.2024

<b>Customer Name &amp; Address</b>		<b>1. Date of receipt : 23.01.2024</b>		
<b>Manappuram Geetha Ravy Public School, Valapad,Mob:9349207835</b>		<b>2. Sampling done by : The Customer</b>		
		<b>3. UID No.of Sample: KWA/QCDL/TSR/S-000466/2024</b>		
		<b>4. Source of sample : Bore Well-Filter Water</b>		
		<b>5. Sample condition : Good</b>		
		<b>6. Name of sample : Drinking water</b>		
		<b>7. Purpose of test : Commercial</b>		
		<b>9. Sample Quantity :100ml</b>		
		<b>9. Test Performing Dates</b> From :24.01.2024 To : 26.01.2024		
		<b>Sl. No.</b>	<b>Parameters</b>	<b>Acceptable limits as per-IS 10500-2012</b>
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	Not Detected
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	Not Detected

Remarks:-Coliform and Ecoli bacteria not detected.

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By Ragesh M.R

Quality Manager,  
Quality Control District Laboratory  
Kerala Water Authority  
Thrissur - 680 005

\* End of Report \*

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1of 1