



DEPARTMENT OF FIRE AND RESCUE SERVICES GOVERNMENT OF KERALA

No:FRS/08/NTKA/29346/2025/FINAL

Date:03/04/2025

NO OBJECTION CERTIFICATE (COMPLETION)

Name & Address of the Applicant:

MANAGING DIRECTOR & CEO

MANAPPURAM FINANCE LIMITED

P.O VALAPPAD THRISSUR, Kerala

680567 India

Name of the Company:

MAGEET SCHOOL

Occupancy type of Building:

Educational Buildings

Height of the building:

12.15 M

Number of Floors of the Building:

G+2(3Floors)

Total Built up Area (in sqm):

4929.07 M²

Survey No:

205/1, 205/1-2, 205/9, 206/2

206/3 206/4-1, 207/1-2, 207/1-5, 207/1-14.

Village:

Valapad

Grama Panchayath:

Valappad

District:

Thrissur

Details of NOC For Permit

FRS/08/NTKA/7896/2022

The above Building was inspected by the authorized and competent Officials of this Department. The final Fire System drawings, the filled up Checklist Cum Application and other Documents produced were scrutinized.

All the necessary fire protection arrangements as per the Rules and Norms pertaining to Fire Safety has been provided in the building and are found to be in good working condition

In the circumstances this No Objection Certificate (Completion) is issued under my Seal and Authority on condition that the Fire Fighting Systems installed will kept always be functional and owner of the Building should take special care to maintain the installed Fire protection arrangements in proper working condition. No further construction will be allowed in the open spaces, in and around the building, provided in the approved plan. This Certificate is issued on the basis of the data made available to the department regarding the site and building and if any of such data is found to be incorrect, this certificate will become invalid.

This Certificate is valid for one year from the date of issue. After one year the Certificate must be renewed. Non Renewal of the Certificate within the time limit will result in loss of eligibility for insurance coverage and appropriate legal action by Local Self Government / Revenue Department. All Officers of and above the rank of Station Officers of the Fire & Rescue Services Department will have the right to Inspect the building on any day / time after serving seven days notice to ensure that the Installed Systems are in good working condition.

This Certificate pertains only to the Fire Fighting arrangements made and installed in the Building. The civil construction, eligibility of the land and plot for this project, environmental feasibility, survey details, etc. shall be got Inspected and Approved by the concerned competent authority.



Digitally signed by SHIJU K K Reacon: final clearance Location:Regional Fire Office Palakkad Date:2025.04.03 01:13:23 +05:30

To,
Applicant / Concerned Local Authority

* This is a computer generated certificate & signature is not required.

Ŕ



GOVERNMENT OF KERALA DEPARTMENT OF FIRE AND RESCUE SERVICES

No.C 22/2024

Office of The Station Officer, Fire & Rescue Station, Nattika. Date: 19.01.2024

NO OBJECTION CERTIFICATE

(RENEWAL)

The board headed by the Station Officer, Fire and Rescue Station, Nattika had inspected Three Storied (G+2) 12.60 Meters height, Educational building (Manappuram Geetha Ravi Public School) in Survey No.205/8, 205/1, 205/2 In Valappad village in Thrissur District under Valappad Grama Panchayath owned by Sri.V.P.Nandakumar, MD & CEO, Manappuram Finance Limited, Valappad, Thrissur and recommended to renew No Objection Certificate No F-1141/2019 dated 27.02.2019 of the Regional Fire Officer, Fire and Rescue Services, Palakkad for the occupation of the said building as per report No.C.22/2024 dated 19.01.2024 of the Station Officer, Fire and Rescue Station, Nattika for one year.

- 2. In the circumstances, this No Objection Certificate is issued under my seal and authority for the continued occupation of the above building. No further construction will be allowed in the vacant spaces provided in the approved plan.
- 3. This certificate is issued on the condition that the firefighting systems installed will be kept always functional and the owner of the building should take special care to maintain the systems installed in proper working condition. This certificate is valid for one year from the date of issue. After one year this certificate must be renewed. Non-renewal of the certificate within the time limit will result in loss of eligibility for insurance coverage and appropriate legal action by the Local Self Government/Revenue Department.

സ്റ്റേഷൻ ഓഫീസർ ഫയർ 9 റെസ്ക്വു സ്റ്റേഷൻ നാട്ടിക – 680 567

Managouram Gestia Revy Public School

Valored