

കേരളസംസ്ഥാന ആരോഗ്യവകുപ്പ്

സ്വയംദൃഷ്ടി പരിപാടി കേന്ദ്രം..... വലപ്പാട്..... ഗ്രാമപഞ്ചായത്ത്
നമ്പർ : 15/13/6/2025

സാനിറ്ററിസർട്ടിഫിക്കറ്റ്

1. LSGD-circular no.66562/Rc3/12/LSGD/dt.10.1.2013
2. Service ACT- no.,O-M-3/30892/12/DHS/Dt.6.6.2014
3. No.16203/AR(12)1/2013/ഉ.ഭ.പ.വ./TVM/dt.8.4.2014

Chalan No.

142007779228202526E

തൃശ്ശൂർ..... വലപ്പാട്..... പഞ്ചായത്തിൽ..... വലപ്പാട്..... പ്രദേശത്ത്..... 111/2448.....
കെട്ടിടത്തിൽ പ്രവർത്തിച്ചുവരുന്ന..... മണപ്പുറം ഗിരിമി പബ്ലിക് സ്കൂൾ.....
..... വലപ്പാട്..... എന്ന സ്ഥാപനത്തിൽ..... 5/6/2025..... തിയ്യതിയിൽ
ഈ സ്ഥാപനത്തിലെ ഹെൽത്ത് ഇൻസ്പെക്ടർ പരിശോധിച്ചു. ടിയൂണിംഗ്.....
കുതിരശക്തിയിൽ പ്രവർത്തിക്കുന്നതും..... സർവ്വേനമ്പർ ശ്രീ./ശ്രീമതി വി.പി.....
നമ്പർ..... വീട്..... എന്ന..... ആളുടെ ഉടമസ്ഥതയിലുമാണ്.
യൂണിറ്റും പരിസരവും പരിശോധിച്ചപ്പോൾ സാനിറ്ററി കണ്ടീഷൻ തൃപ്തികരമാണെന്ന്
ബോധ്യമായി. പഞ്ചായത്തിൽ നിന്ന് ലൈസൻസിനുവേണ്ടിതാഴെ പറയുന്ന വ്യവസ്ഥകൾക്കും
നിബന്ധനകൾക്കും വിധേയമായി സ്ഥാപനത്തിന് സാനിറ്ററിസർട്ടിഫിക്കറ്റ് അനുവദിക്കുന്നു.

1. പൊതുജനാരോഗ്യം ശല്യമുണ്ടാക്കാത്ത രീതിയിൽ സ്ഥാപനം പ്രവർത്തിക്കണം
2. മാലിന്യം പൊതുജനാരോഗ്യത്തിന് ഹാനികരമല്ലാത്ത വിധത്തിൽ ശാസ്ത്രീയമായി നീക്കം ചെയ്യണം.
3. ജലസ്രോതസ്സും മറ്റും സംക്രമികരോഗങ്ങൾ ഉണ്ടാക്കാത്ത വിധത്തിൽ സംരക്ഷിക്കണം
4. ഈ സ്ഥാപനത്തിൽ നിന്ന് വായു, ശബ്ദം മലിനീകരണം ഉണ്ടാകുന്ന പ്രവർത്തനം പാടില്ല.
5. സ്ഥാപനവും പരിസരവും സംക്രമികരോഗങ്ങൾ ഉണ്ടാക്കാത്ത രീതിയിൽ സംരക്ഷിക്കണം
6. ജീവനക്കാർ സംക്രമികരോഗങ്ങളിൽ നിന്നും മുക്തരായിരിക്കേണ്ടതാണ്.
7. പുകയിലമുക്തം സൈൻ ബോർഡ് പ്രദർശിപ്പിച്ചിരിക്കേണ്ടതും സ്ഥാപനം പുകവലി മുക്തമെന്ന് ഉറപ്പു വരുത്തണം.
8. അന്യസംസ്ഥാന തൊഴിലാളികളിൽ സ്ഥാപനത്തിൽ ഉണ്ടെങ്കിൽ അടുത്തുള്ള പ്രാഥമികാരോഗ്യ കേന്ദ്രത്തിലെ മെഡിക്കൽ ഓഫീസറെ അറിയിക്കേണ്ടതാണ്.
9. പ്ലാസ്റ്റിക് മാലിന്യം പരിസരത്ത് കെട്ടിക്കുകയോ വലിച്ചെറിയുകയോ ചെയ്യരുത്. പ്ലാസ്റ്റിക് മാലിന്യം ശേഖരിച്ച് ശാസ്ത്രീയമായി സംസ്കരിക്കുക.
10. പൊതുജനാരോഗ്യനിയമം (MPH ACT/TCPH ACT), പഞ്ചായത്ത് രാജ് നിയമവും ചട്ടങ്ങളും മറ്റ് ബന്ധപ്പെട്ട നിയമങ്ങളും നടപടി ക്രമങ്ങളും പാലിച്ചിരിക്കണം
11. ഭാവിയിൽ ഏതെങ്കിലും തരത്തിലുള്ള വികസന പ്രവർത്തനങ്ങൾക്ക് ഈ ആഫീസിൽ നിന്നും ലഭിക്കുന്ന അനുമതിക്ക് വിധേയമായിരിക്കണം.
12. ഓരോദിവസവും ഈ സ്ഥാപനത്തിന്റെ പ്രവർത്തനം കഴിഞ്ഞശേഷം പൊതുജനാരോഗ്യശല്യം ഉണ്ടാക്കാത്ത രീതിയിൽ വൃത്തിയാക്കി സൂക്ഷിക്കേണ്ടതാണ്
13. മുകളിൽ പറഞ്ഞ നിബന്ധനകളിൽ ഏതെങ്കിലും പാലിക്കാതെ വന്നാൽ മറ്റൊരു അറിയിപ്പും കൂടാതെ സാനിറ്ററി സർട്ടിഫിക്കറ്റ് റദ്ദുചെയ്യുന്നതാണ്.



സ്വയംദൃഷ്ടി പരിപാടി കേന്ദ്രം.....

ഹെൽത്ത് ഇൻസ്പെക്ടർ
ഹെൽത്ത് ഇൻസ്പെക്ടർ
.....
.....
.....

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 40/15/9/2023

Dated: 14-03-2024

It is certified that an inspection team headed by.....SUBAR. A. A. Health Inspector (Name of Officers with designation) from.....PHED

inspected the.....Manappuram Geetha Ravi Public School

...P.O. Valappad.....(Name & Address of the

school) on.....13-03-2024.....(date of inspection) and on the basis of Water Test Report

(Attached) bearing no. KWA/WCDL/TBR dated 0466/2024 27-01-2024 of

.....(PHED Lab) certified that

the.....Manappuram Geetha Ravi Public School.....

(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till.....12-03-2025.....



To

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: C.H.C. Valappad

സംസ്ഥാന ആരോഗ്യ സെക്ഷൻ
കമ്മ്യൂണിറ്റി ഹെൽത്ത് സെന്റർ
വലപ്പാട് (താലൂക്ക്)

(Name & Address of the Institution)

PRINCIPAL
Manappuram Geetha Ravi Public School
Valappad



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA THRISSUR

Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com



TC-10416

Test Report

Test Report. No :KWA/QCDL/TSR/0466/2024

ULR No.: TC1041524000000409F

Report Date: 27.01.2024

Customer Name & Address			1. Date of receipt : 23.01.2024		
Manappuram Geetha Ravy Public School, Valapad,Mob:9349207835			2. Sampling done by : The Customer		
			3. UID No.of Sample: KWA/QCDL/TSR/S-000466/2024		
			4. Source of sample : Bore Well-Filter Water		
			5. Sample condition : Good		
			6. Name of sample : Drinking water		
			7. Purpose of test : Commercial		
			8. Sample quantity : 2 litre		
			9. Test performing dates		
			From :24.01.2024 To : 24.01.2024		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Turbidity	(NTU)	IS 3025 (part 10) - 2023 Nephelometric method	1	0.45
2	pH at 25°C		IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	6.9
3	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (part 21)-2009 (Reaffirmed. 2019)EDTA titration method	200	2.0
4	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 1988 (Reaffirmed. 2019) Argentometric titration	250	3.9
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2003 (Reaffirmed. 2019) 1,10 Phenanthroline method	1.0	0.39
6	Nitrate (as NO ₃)	(mg/litre)	APHA 4500 - NO ₃ B.Ultraviolet screening method	45	0.57

Remarks:-All tested parameters are within the acceptable limit.

NB:- The results stated above related only to the samples submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By Ragesh M.K

Quality Manager,
Quality Control District Laboratory
Kerala Water Authority

KWA/QCDL/TSR-R-No:6	Issue No:2
Amend.No: 03	Amend Date: 08.08.2023

Issue Date: 27.01.2024
Page No: 1
Manappuram Geetha Ravy Public School
Valapad



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA THRISSUR

Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com

Test Report

Report Date : 27.01.2024

Test Report. No : KWA/QCDL/TSR/0466/2024

Customer Name & Address Manappuram Geetha Ravy Public School, Valapad, Mob:9349207835			1. Date of receipt : 23.01.2024		
			2. Sampling done by : The Customer		
			3. UID No.of Sample: KWA/QCDL/TSR/S-000466/2024		
			4. Source of sample : Bore Well-Filter Water		
			5. Sample condition : Good		
			6. Name of sample : Drinking water		
			7. Purpose of test : Commercial		
			8. Sample quantity : 2 litre		
			9. Test performing dates From :24.01.2024 To : 24.01.2024		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity	(micro mhos/cm)	IS 3025 (part 14) - 2013 (Reaffirmed. 2019) Electrometric method	-	87.0

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By Ragesh M.K

Quality Manager,
Quality Control District Laboratory
Kerala Water Authority

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2025
Rev.No: 00	Rev Date: 00	Page 1 of 1 Thrissur - 680 005

[Signature]
PRINCIPAL
Manappuram Geetha Ravy Public School
Valapad



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

Test Report

Test Report. No :KWA/QCDL/TSR/0466/2024

Report Date : 27.01.2024

Customer Name & Address			1. Date of receipt : 23.01.2024	
Manappuram Geetha Ravy Public School, Valapad,Mob:9349207835			2. Sampling done by : The Customer	
			3. UID No.of Sample: KWA/QCDL/TSR/S-000466/2024	
			4. Source of sample : Bore Well-Filter Water	
			5. Sample condition : Good	
			6. Name of sample : Drinking water	
			7. Purpose of test : Commercial	
			9. Sample Quantity :100ml	
			9. Test Performing Dates	
			From :24.01.2024	To : 26.01.2024
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	Not Detected
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	Not Detected

Remarks:-Coliform and Ecoli bacteria not detected.

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By Ragesh M.R

Quality Manager,
Quality Control District Laboratory
Kerala Water Authority
Thrissur - 680 005

* End of Report *

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1of 1

Signature

PRINCIPAL
Manappuram Geetha Ravy Public School
Valapad